



**Bid Document** 

| Bid Document  |   |  |  |  |  |  |
|---|---|--|--|--|--|--|
| Bid Details   |   |  |  |  |  |  |
| Bid End Date/Time   | 01-02-2021 16:00:00   |  |  |  |  |  |
| Bid Opening Date/Time   | 01-02-2021 16:30:00   |  |  |  |  |  |
| Bid Life Cycle (From Publish Date)                                    | 90 (Days)   |  |  |  |  |  |
| Bid Offer Validity (From End Date)                                    | 30 (Days)   |  |  |  |  |  |
| Ministry/State Name   | Assam   |  |  |  |  |  |
| Department Name   | Education Department Assam  |  |  |  |  |  |
| Organisation Name   | Directorate Of Higher Education   |  |  |  |  |  |
| Office Name   | Dibrugarh   |  |  |  |  |  |
| Total Quantity  | 15  |  |  |  |  |  |
| Item Category   | Hot and Cold Air Conditioners   |  |  |  |  |  |
| MSE Exemption for Years of Experience and Turnover                    | No  |  |  |  |  |  |
| Startup Exemption for Years of Experience and Turnover                | No  |  |  |  |  |  |
| Document required from seller   | Experience Criteria, Bidder Turnover, Certificate (Requested in ATC), OEM Authorization Certificate, OEM Annual Turnover, Additional Doc 1 (Requested in ATC), Additional Doc 2 (Requested in ATC), Additional Doc 3 (Requested in ATC), Additional Doc 4 (Requested in ATC) *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer |  |  |  |  |  |
| Bid to RA enabled   | No  |  |  |  |  |  |
| Time allowed for Technical Clarifications during technical evaluation | 3 Days  |  |  |  |  |  |
| Inspection Required   | No  |  |  |  |  |  |
| Evaluation Method   | Total value wise evaluation   |  |  |  |  |  |
|   |   |  |  |  |  |  |

### **EMD Detail**

| ſ         |      |
|-----------|------|
| Required  | No   |
| Trequired | 1.10 |

# ePBG Detail

| Required | No |
|----------|----|
|----------|----|

# Splitting

Bid splitting not applied.

# Hot And Cold Air Conditioners (15 pieces)

#### **Technical Specifications**

#### \* As per GeM Category Specification

| Specification Specification Name |  | Bid Requirement (Allowed Values)  |  |  |
|----------------------------------|--|---|--|--|
| CAPACITY / GENERIC               | Type of Air Conditioner  | High wall Split AC (Hot and Cold)   |  |  |
|                                  | Compressor (Speed Type)  | Non- Inverter (Fixed Speed)   |  |  |
|                                  | Heating Mechanism  | Heat Pump   |  |  |
|                                  | Nominal Capacity (TR)  | 2   |  |  |
|                                  | Nominal Cooling Capacity<br>(kcal/hr)  | 6000 for 2.0 TR   |  |  |
|                                  | Nominal Heating Capacity   | 90 to 100% of Cooling Capacity, 101 to 110% of Cooling Capacity   |  |  |
|                                  | Coil Material (Evaporator)   | Copper  |  |  |
|                                  | Coil Material (Condensor)  | Copper  |  |  |
|                                  | Fin Material (Evaporator)  | Copper, Aluminium   |  |  |
|                                  | Fin Material (Condensor)   | Copper, Aluminium   |  |  |
|                                  | Eco-friendly refrigerant   | Yes   |  |  |
|                                  | BEE Star Rating  | 3   |  |  |
|                                  | Features   | Auto restart, Sleep mode, 24 hour On-Off Timer, Power Saver, Turbo cool, Self clean, 2-way air swing, 4-way air swing, Speed settings, Humidity Control, Active carbon filter, Anti-Bacteria Filter, Cyclotron filter |  |  |
|                                  | Minimum length of copper pipe and suitable connecting electrical cable for installation and commissioning - inclusive in the scope of supply | 3 metre, 5 metre  |  |  |
| WARRANTY &                       | Warranty on machine  | 1.0   |  |  |
| INSTALLATION                     | Warranty on Compressor   | 5.0   |  |  |
|                                  | Installation and<br>Commissioning  | With Installation and Commissioning   |  |  |

#### **Consignees/Reporting Officer and Quantity**

| S.N | lo. | Consignee/Reporting<br>Officer | Address   | Quantity | Delivery Days |
|-----|-----|--------------------------------|---|----------|---------------|
| 1   |     | Debasish Nath                  | 786004,Dibrugarh University<br>Institute of Engineering and<br>Technology, Dibrugarh University,<br>Dibrugarh, Assam. | 15       | 15            |

# **Bid Specific Additional Terms and Conditions**

1. Warranty period of the supplied products shall be 2 years from the date of final acceptance of goods or after completion of installation, commissioning & testing of goods (if included in the scope of supply), at consignee location. OEM Warranty certificates must be submitted by Successful Bidder at the time of delivery of Goods. The seller should guarantee the rectification of goods in case of any break down during the guarantee period. Seller should have well established Installation, Commissioning, Training, Troubleshooting and Maintenance Service

group in INDIA for attending the after sales service. Details of Service Centres near consignee destinations are to be uploaded along with the bid.

#### This Bid is also governed by the General Terms and Conditions

In terms of GeM GTC clause 26 regarding Restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake compliance of this and any false declaration and non-compliance of this would be a ground for immediate termination of the contract and further legal action in accordance with the laws.

#### ---Thank You---